Brandschutz Entrauchung Differenzdruckanlagen Lüftungssysteme



Declaration of Performance

DoP/RKI/005

| (1) Product | RKI |
|--|-------|
| Unique identification code of the product type | TAIKI |

(2) Intended use Smoke control damper for multi compartments

(3) Manufacturer Strulik GmbH

Neesbacher Str. 15

65597 Hünfelden, Deutschland

(5) System of assessment, verification of constancy of

performance

EN 12101-8:2011

0761-CPR-0575

System 1

(6) Harmonized standard Notified body/bodies

The notified body 0761, MPA Braunschweig, carried out the initial inspection of the manufacturing plants and of the factory production control as well as the continuous surveillance, assessment and evaluation of factory production control according to System 1 of the Contruction Products Regulation and issued the certificate of constancy of performance:

(7) Declared performance according to EN 12101-8:2011

EI 90 (vedw, hod i \leftrightarrow o) S 1000 C10000 HOT400/30 MA multi EI 120 (vew i \leftrightarrow o) S 1000 C10000 HOT400/30 MA multi

Essential characteristics (maximum dimension [mm] W 1000 x H 1000)

| | Performance class |
|--|-------------------|
| Nominal activation conditions/ sensitivity | pass |
| Response delay/ response time | pass |
| Operational reliability | pass |
| Integrity E | pass |
| Insulation I | pass |
| Smoke leakage S (EIS) | pass |
| Mechanical stability (under E) | pass |
| Querschnittserhalt (unter E) | pass |
| Maintenance of the cross section (under E) | pass |
| Durability of response delay | pass |
| Durability of operational reliability | pass |
| | |

Strulik GmbH

Brandschutz Entrauchung Differenzdruckanlagen Lüftungssysteme



| Essential characteristics | | |
|---|-------------------|--|
| | Performance class | |
| Response delay MA | pass | |
| Mounting in concrete wall, thickness ≥ 100mm, density ≥ 650 +/-200 kg/m³ | pass | |
| Mounting in light partition wall, thickness ≥ 100mm | pass | |
| Mounting in concrete ceiling, thickness ≥ 150mm, density ≥ 650 +/-200 kg/m³ | pass | |
| Mounting in and on horizontal ducts according to EN 1366-8 | pass | |
| Mounting in and on vertical ducts according to EN 1366-8 | pass | |
| Mounting in connection with horizontal ducts according to EN 1366-9 | pass | |
| Mounting in connection with vertical ducts according to EN 1366-9 | pass | |
| Mounting in connection with horizontal ducts according to EN 1366-1 | pass | |
| Mounting in connection with vertical ducts according to EN 1366-1 | pass | |

The performance of the product identified above is in conformity with the declared performance. This declaration of performance is issued with regulation (EU) No. 305/2011, under the sole resposibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Hünfelden, June 03rd 2024

Stephan Eidmann Managing director

Exact attention should be paid to the manufacturer's mounting manual in order to meet and obtain the declared performance of this fire damper.