



ETA-Danmark A/S  
Göteborg Plads 1  
DK-2150 Nordhavn  
Tel. +45 72 24 59 00  
Internet [www.etadanmark.dk](http://www.etadanmark.dk)

Authorised and notified according  
to Article 29 of the Regulation (EU)  
No 305/2011 of the European  
Parliament and of the Council of 9  
March 2011

MEMBER OF EOTA



## European Technical Assessment ETA-25/00468 of 2025/05/16

### I General Part

**Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: ETA-Danmark A/S**

Trade name of the  
construction product:

PXG

Product family to which the  
above construction product  
belongs:

Air Transfer Grilles

Manufacturer:

Strulik GmbH  
Neesbacher Straße 15  
DE-65597 Hünfelden  
Telephone: +49 6438 8390  
[www.strulik.com](http://www.strulik.com)

Manufacturing plant:

Werk K

This European Technical  
Assessment contains:

9 pages including 4 annex which form an integral part of  
the document

This European Technical  
Assessment is issued in  
accordance with Regulation  
(EU) No 305/2011, on the  
basis of:

EAD 351141-00-1104:  
Fire-resistant Reactive Air Transfer Grilles

This version replaces:

-

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full (excepted the confidential Annex(es) referred to above). However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

## II SPECIFIC PART OF THE EUROPEAN TECHNICAL ASSESSMENT

### 1 Technical description of product

The air transfer grill system PXG consists mainly of round shaped and rectangular shaped air transfer grilles which are made of intumescent fire protection rigid foam based on polyurethane with a free cross-section of 51%.

The air transfer grill must be applied in the center of the opening. PXG can be attached to bigger sizes with adhesive CB 2011, a fast-curing cyanoacrylate in dimension  $\leq 450 \times 450$  mm. (9 pcs of PXG).




Figure 1: Types of intumescent air transfer grilles.

PXG must be fixed in the opening with ZZ 333, an intumescent pasty, brushable mastic on basis of acrylate with intumescent fire protection additives. The surface of the opening on both sides must be covered with one of the following elements:

Element name	Type	Application
GK-150-B286X286-18	Decorative cover	On both sides of the wall
GK-150-B388X184-18		
GK-150-B508X522-18		
RK-200	Smoke flap	On the non-fire side of the rigid wall (in conjunction with decorative cover)

Table 1: Covering for surface of the openings

Air transfer grilles are intended to maintain the fire resistance of the separating element at the position, where installed to provide path for ventilation. In case of fire such path shall be sealed automatically.

The air transfer grilles are installed in a 100 mm thick aerated concrete ( $350 \text{ kg/m}^3$ ) wall as well as 100 mm thick flexible wall construction (2x 12.5 mm type F (EN 520) gypsum boards on each side and 40 mm thick mineral wool insulation ( $100 \text{ kg/m}^3$ )).

### 2 Specification of the intended use(s) in accordance with the applicable European Assessment Document (hereinafter EAD)

Air transfer grilles are incorporated into various elements of a building structure (walls, floors and doors) to provide paths for ventilation and to enable such paths to be sealed automatically into a fire situation.

More information in table, section 3: "Performance of the product and references to the methods used for its assessment".

Concerning product packaging, transport, storage, maintenance, replacement and repair it is the responsibility of the manufacturer to undertake the appropriate measures and to advise their clients on the transport, storage, maintenance, replacement and repair of the product, as the manufacturer considers necessary.

It is assumed that the product will be installed according to the manufacturer's instructions or (in absence of such instructions) according to the usual practice of the building professional.

The provisions made in this European Technical Assessment are based on an assumed working life of the air transfer grilles of 10 years when installed in the works.

The indications given on the working life cannot be interpreted as a guarantee given by the manufacturer or the Assessment Body but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

### 3 Performance of the product and references to the methods used for its assessment.

Characteristic	Assessment of characteristic
<b>3.2 Safety in case of fire (BWR 2)</b>	
Reaction to fire	<b>No performance assessed</b>
Resistance to fire	Classified according to EN 13501-2, see information in annex A.
<b>3.3 Hygiene, health and the environment (BWR 3)</b>	
Air permeability	<b>No performance assessed</b>
<b>3.4 Safety and accessibility in use (BWR 4)</b>	
Durability	Use category: <b>Type Z<sub>2</sub></b>
Expansion ratio after exposure to environmental conditions	<b>No performance assessed</b>
Expansion pressure after exposure to environmental conditions	<b>No performance assessed</b>
Compatibility of materials – change of appearance	<b>No performance assessed</b>

See additional information in section 3.8-3.9.

#### 3.8 Methods of verification

The assessment of the performance of the PXG Air Transfer Grilles in relation to the applicable BWR's has been made in accordance with the European Assessment Document (EAD) no. EAD 351141-00-1104: Fire-resistant Reactive Air Transfer Grilles.

Fire-resistant air transfer grilles covered by this EAD are intended for use in internal conditions of type Z<sub>2</sub> in accordance with EAD 351141-00-1104 (intended for conditions with humidity lower than 85 % RH, excluding temperatures below 0 °C, without exposure to rain or UV).

The PXG Air Transfer Grilles are manufactured in accordance with the provisions of this European Technical Assessment using the manufacturing processes as identified in the inspection of the plant by the notified inspection body and laid down in the technical documentation.

#### 3.9 General aspects related to the fitness for use of the product.

The European Technical Assessment is issued for the product based on agreed data/information, deposited with ETA-Danmark, which identifies the product that has been assessed and judged. Changes to the product or production process, which could result in this deposited data/information being incorrect, should be notified to ETA-Danmark before the changes are introduced. ETA-Danmark will decide if such changes affect the ETA and consequently the validity of the CE marking based on the ETA and if so whether further assessment or alterations to the ETA, shall be necessary.

#### **4 Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base.**

##### **4.1 AVCP system**


According to the Decision 1999/454/EC amended by Decision 2001/596/EC, the system(s) of assessment and verification of constancy of performance (see Annex III to Regulation (EU) No 305/2011) is **1**.

In addition, with regard to reaction to fire for products covered by this EAD the applicable European legal act is Decision 1999/454/EC amended by Decision 2001/596/EC the system(s) of assessment and verification of constancy of performance (see Annex III to Regulation (EU) No 305/2011) is **1**.

#### **5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD.**

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at ETA-Danmark prior to CE marking.



Issued in Copenhagen on 2025-05-16 by



Thomas Bruun  
Managing Director, ETA-Danmark

'PXG' with depth  $\geq 40$  mm installed in the center of the opening using fire protection sealant 'ZZ 333' to fix the air transfer grille with a resulting annular gap  $\leq 5$  mm between the grille and the perimeter of the opening.

A metal sheet cover grid has to be mounted as per manufacturers installation instructions in front of the opening on each surface of the wall.

<p>a: 'PXG' for opening sizes <math>\leq \varnothing 210</math></p> 	<p>b: 'PXG' for opening sizes <math>\leq 360 \times 160</math></p> 						
<p>Classification: E 120 / EI 90</p>	<p>Classification: E 120 / EI 90</p>						
<table><tr><td data-bbox="186 1328 494 1440"><p>1: <u>Rigid wall</u> thickness <math>\geq 100</math> mm density <math>\geq 350</math> kg/m<sup>3</sup></p></td><td data-bbox="633 1328 893 1440"><p>3a: 'PXG' size <math>\leq \varnothing 200</math> mm depth <math>\geq 40</math> mm</p></td><td data-bbox="1058 1328 1402 1440"><p>4a: <u>Covering</u> 'GK-150-B286X286-18' (see Annex A.1)</p></td></tr><tr><td data-bbox="186 1462 494 1541"><p>2: <u>'ZZ 333'</u> annular gap <math>\leq 5</math> mm</p></td><td data-bbox="633 1462 997 1574"><p>3b: 'PXG' (<math>\leq 2</math> pcs.) size <math>\leq 350</math> mm x 150 mm depth <math>\geq 40</math> mm</p></td><td data-bbox="1058 1462 1402 1574"><p>4b: <u>Covering</u> 'GK-150-B388X184-18' (see Annex A.1)</p></td></tr></table>		<p>1: <u>Rigid wall</u> thickness <math>\geq 100</math> mm density <math>\geq 350</math> kg/m<sup>3</sup></p>	<p>3a: 'PXG' size <math>\leq \varnothing 200</math> mm depth <math>\geq 40</math> mm</p>	<p>4a: <u>Covering</u> 'GK-150-B286X286-18' (see Annex A.1)</p>	<p>2: <u>'ZZ 333'</u> annular gap <math>\leq 5</math> mm</p>	<p>3b: 'PXG' (<math>\leq 2</math> pcs.) size <math>\leq 350</math> mm x 150 mm depth <math>\geq 40</math> mm</p>	<p>4b: <u>Covering</u> 'GK-150-B388X184-18' (see Annex A.1)</p>
<p>1: <u>Rigid wall</u> thickness <math>\geq 100</math> mm density <math>\geq 350</math> kg/m<sup>3</sup></p>	<p>3a: 'PXG' size <math>\leq \varnothing 200</math> mm depth <math>\geq 40</math> mm</p>	<p>4a: <u>Covering</u> 'GK-150-B286X286-18' (see Annex A.1)</p>					
<p>2: <u>'ZZ 333'</u> annular gap <math>\leq 5</math> mm</p>	<p>3b: 'PXG' (<math>\leq 2</math> pcs.) size <math>\leq 350</math> mm x 150 mm depth <math>\geq 40</math> mm</p>	<p>4b: <u>Covering</u> 'GK-150-B388X184-18' (see Annex A.1)</p>					




PXG	Annex A
<p><b>Rigid wall constructions with wall thickness <math>\geq 100</math> mm</b> <b>PXG with metal grid cover on both sides of the wall</b></p>	

'PXG' with depth  $\geq 50$  mm installed in the center of the opening using fire protection sealant 'ZZ 333' to fix the air transfer grille with a resulting annular gap  $\leq 5$  mm between the grille and the perimeter of the opening.

For walls with thickness  $< 112.5$  mm, the wall has to be fitted with a board frame,  $\geq 50$  mm wide, around the opening. At least 1 layer of  $\geq 12.5$  mm thick type F gypsum boards can be used.

The board frame has to be fixed with suitable screws at a distance  $\leq 200$  mm.

A metal sheet cover grid has to be mounted as per manufacturers installation instructions in front of the opening on each surface of the wall.

<p>a: 'PXG' for opening sizes <math>\leq \varnothing 210</math></p> 	<p>b: 'PXG' for opening sizes <math>\leq 360 \times 160</math></p> 	<p>c: 'PXG' for opening sizes <math>\leq 460 \times 460</math></p> 
<p>Classification: E 120 / EI 90</p>	<p>Classification: E 120 / EI 120</p>	<p>Classification: E 120 / EI 90</p>
<p>1: <u>Rigid wall</u> thickness <math>\geq 100</math> mm density <math>\geq 350 \text{ kg/m}^3</math></p> <p>2: <u>Type F gypsum board</u> size <math>\geq 12.5 \text{ mm} \times 50 \text{ mm}</math> density <math>\geq 450 \text{ kg/m}^3</math></p> <p>3: <u>'ZZ 333'</u> annular gap <math>\leq 5</math> mm</p>	<p>4a: <u>'PXG'</u> size <math>\leq \varnothing 200</math> mm depth <math>\geq 50</math> mm</p> <p>4b: <u>'PXG'</u> size <math>\leq 300 \text{ mm} \times 150 \text{ mm}</math> depth <math>\geq 50</math> mm</p> <p>4c: <u>'PXG'</u> size <math>\leq 450 \text{ mm} \times 450 \text{ mm}</math> depth <math>\geq 50</math> mm</p>	<p>5a: <u>Covering</u> 'GK-150-B286X286-18' (see Annex A.1)</p> <p>5b: <u>Covering</u> 'GK-150-B388X184-18' (see Annex A.1)</p> <p>5c: <u>Covering</u> 'GK-150-B508X522-18' (see Annex A.1)</p>


PXG	Annex A
<p><b>Rigid wall constructions with wall thickness <math>\geq 100</math> mm</b>  <b>PXG with metal grid cover on both sides of the wall</b></p>	



'PXG' with depth  $\geq 40$  mm installed in the center of the opening using fire protection sealant 'ZZ 333' to fix the air transfer grille with a resulting annular gap  $\leq 5$  mm between the grille and the perimeter of the opening.

The opening has to be lined with at least 2 layer of  $\geq 12.5$  mm thick type F gypsum boards. A metal sheet cover grid has to be mounted as per manufacturers installation instructions in front of the opening on each surface of the wall.

'PXG' for opening sizes  $\leq 360 \times 160$



Classification:

E 120 / EI 120

1: Flexible wall

thickness  $\geq 100$  mm

3: 'ZZ 333'

annular gap  $\leq 5$  mm

5: Covering

'GK-150-B388X184-18'  
(see Annex A.1)

2: Type F gypsum board lining

depth: 2 layers  $\geq 12.5$  mm  
density  $\geq 450$  kg/m<sup>3</sup>

4: 'PXG'

size  $\leq 300$  mm x 150 mm  
depth  $\geq 40$  mm

PXG	Annex A
<b>Flexible wall constructions with wall thickness <math>\geq 100</math> mm PXG with metal grid cover both sides of the wall</b>	



'PXG' with depth  $\geq 50$  mm installed in the center of the opening using fire protection sealant 'ZZ 333' to fix the air transfer grille with a resulting annular gap  $\leq 5$  mm between the grille and the perimeter of the opening.


The opening has to be lined with 50 mm wide steel studs on top of the mineral wool insulation and additionally at least 2 layer of  $\geq 12.5$  mm thick type F gypsum boards.

For walls with thickness  $< 112.5$  mm, the wall has to be fitted with a board frame,  $\geq 50$  mm wide, around the opening. At least 1 layer of  $\geq 12.5$  mm thick type F gypsum boards can be used.

The board frame has to be fixed with suitable screws at a distance  $\leq 200$  mm.

A metal sheet cover grid has to be mounted as per manufacturers installation instructions in front of the opening on each surface of the wall.

'PXG' for opening sizes  $\leq 460 \times 460$



Classification:

E 120 / EI 120

- |   |   |   |
|---|---|---|
| 1: <u>Flexible wall</u><br>thickness $\geq 100$ mm  | 3: <u>'ZZ 333'</u><br>annular gap $\leq 5$ mm   | 5: <u>Covering</u><br>'GK-150-B508X522-18'<br>(see Annex A.1) |
| 2: <u>Type F gypsum board frame</u><br>size $\geq 12.5$ mm x 50 mm<br>density $\geq 450\text{kg/m}^3$       | 4: <u>'PXG'</u> ( $\leq 9$ pcs.)<br>size $\leq 450$ mm x 450 mm<br>depth $\geq 50$ mm<br><u>'PXG'</u> ( $\leq 2$ pcs.)<br>size $\leq 360$ mm x 160 mm<br>depth $\geq 40$ mm |   |
| <u>Type F gypsum board lining</u><br>depth: 2 layers $\geq 12.5$ mm<br>density $\geq 450$ kg/m <sup>3</sup> |   |   |

**PXG**

**Annex A**

**Flexible wall constructions with wall thickness  $\geq 100$  mm**  
**PXG with metal grid cover both sides of the wall**